EXHIBIT E

LETTER FROM CUNDEY
GEOTECHNICAL CONSULTANTS,
INC. DATED DECEMBER 8, 2008

December 8, 2008
CGC 1011.001

Steve Hafener
121 Brookline Street
Moraga, CA 94556

Architectural Plan Review
Planned Residential Addition and Deck
121 Brookline Street
Moraga, California

Dear Mr. Hafener:

Per your architect's request, the undersigned Cundey Geotechnical Consultants, Inc. (CGC) engineer has reviewed a partial set of architectural drawings for the referenced project. The plan review was requested because the locations of the planned improvements, specifically, the residential addition and planned decks, have been altered from those shown on the Site Plan (Figure 3) presented in CGC's Geological and Geotechnical Investigation report for the project dated September 10, 2008. The addition originally planned off the rear left corner of the house has been relocated to the right side, and is smaller.

Based on our review, it is CGC's opinion that the recommendations presented in our report for the project remain valid. CGC drilled a test boring (Boring 2) close to the planned addition on the right side, and determined that bedrock of the Orinda Formation was shallow, as was the case in Boring 1, located in the area of the originally planned addition.

We appreciate the opportunity to provide geotechnical engineering and geological services to you. If you have any questions, please call.

Very truly yours,

Thomas E. Cundey

Thomas E. Cundey
Geotechnical Engineer 2058

REGISTERED PROFESSIONAL ENGINEER
THOMAS E. CUNDEY
GE 2058
EXP 6/30/2010
GEOTECHNICAL
STATE OF CALIFORNIA

2 copies submitted

cc: J. Allen Sayles Architects (3 copies)

Cundey Geotechnical Consultants, Inc.
P.O. Box 5562, Walnut Creek, CA 94596
Phone: 925-938-4895 FAX: 925-938-7983